

HPF CEQMS data from OCT-DEC-2019				
Date	Recovery boiler stack		Lime killen Stack	
	FLOW	SPM	FLOW	SPM
	m3/hour	mg/m3	m3/hour	mg/m3
Max Limit	106000 m3/Hr	150 mg/m3	18000 m3/Hr	150 mg/m3
01.10.2019	54760	60.65	10473	52.08
02.10.2019	54921	72.41	10588	56.69
03.10.2019	55011	71.56	10653	56.36
04.10.2019	54859	81.82	10544	60.38
05.10.2019	54723	70.26	10446	55.85
06.10.2019	54891	56.56	10567	50.48
07.10.2019	54522	60.85	10302	52.16
08.10.2019	54666	77.91	10405	58.85
09.10.2019	54715	67.53	10440	54.78
10.10.2019	54498	59.34	10285	51.56
11.10.2019	54609	63.66	10364	53.26
12.10.2019	54662	74.19	10402	57.39
13.10.2019	54494	78.8	10282	59.2
14.10.2019	54664	66.02	10404	54.18
15.10.2019	54456	59.9	10255	51.79
16.10.2019	54521	76.93	10301	58.46
17.10.2019	54444	61.57	10246	52.44
18.10.2019	54674	66.68	10411	54.44
19.10.2019	54646	76.81	10391	58.42
20.10.2019	54470	78.14	10264	58.94
21.10.2019	54711	64.61	10438	53.63
22.10.2019	54761	78.85	10474	59.22
23.10.2019	54330	58.86	10164	51.38
24.10.2019	54335	63.57	10167	53.22
25.10.2019	54483	84.69	10274	61.51
26.10.2019	54377	80.94	10198	60.04
27.10.2019	54163	67.96	10044	54.94
28.10.2019	54184	63.29	10059	53.11
29.10.2019	53920	59.94	9870	51.8
30.10.2019	54312	62.72	10151	52.89
31.10.2019	55379	84.33	10917	61.37
01.11.2019	53218	70.62	11471	58.45
02.11.2019	53833	71.75	9807	56.43
03.11.2019	54246	73.36	10104	57.06
04.11.2019	54160	67.94	10042	54.94
05.11.2019	53868	66.68	9832	54.44
06.11.2019	54218	68.93	10083	55.33
07.11.2019	54707	76.32	10434	58.22
08.11.2019	54428	75.39	10234	57.86
09.11.2019	54450	71.61	10250	56.38
10.11.2019	54403	70.22	10217	55.83
11.11.2019	54376	66.62	10197	54.42

12.11.2019	54343	67.01	10173	54.57
13.11.2019	54326	65.88	10161	54.13
14.11.2019	54468	68.13	10263	55.01
15.11.2019	54681	67.75	10416	54.86
16.11.2019	54542	72.05	10316	56.55
17.11.2019	54435	65.35	10239	53.92
18.11.2019	54515	63.31	10297	53.12
19.11.2019	54486	64.29	10276	53.51
20.11.2019	54447	62.45	10248	52.79
21.11.2019	54618	64.14	10371	53.45
22.11.2019	54639	68.27	10386	55.06
23.11.2019	54380	65.43	10199	53.95
24.11.2019	54598	66.51	10356	54.37
25.11.2019	54530	67.82	10307	54.89
26.11.2019	54640	66.33	10386	54.31
27.11.2019	54684	68.03	10418	54.97
28.11.2019	54649	63.89	10393	53.35
29.11.2019	54517	58.45	14561	73.36
30.11.2019	54515	62.64	12198	52.86
01.12.2019	55009	66.26	14651	54.28
02.12.2019	55528	77.62	15024	58.73
03.12.2019	54973	67.62	14626	54.81
04.12.2019	54727	64.73	14449	53.68
05.12.2019	54785	64.1	14490	53.43
06.12.2019	54862	65.49	14546	53.98
07.12.2019	54843	65.63	14532	54.03
08.12.2019	54933	64.49	14597	53.59
09.12.2019	54782	60.1	14488	51.86
10.12.2019	54940	62.6	14602	52.85
11.12.2019	54465	57.1	13125	50.69
12.12.2019	54592	55.6	11966	50.1
13.12.2019	54665	58.9	12019	51.39
14.12.2019	54717	63.35	12056	53.14
15.12.2019	54689	59.51	12036	51.63
16.12.2019	54639	57.95	12000	51.02
17.12.2019	54687	58	11747	51.04
18.12.2019	54869	53.1	11586	49.12
19.12.2019	54926	57.09	11627	50.68
20.12.2019	55038	57.46	11708	50.83
21.12.2019	54847	57.75	11571	50.94
22.12.2019	54783	59.92	11524	51.79
23.12.2019	54779	57.45	11521	50.82
24.12.2019	54730	57.88	11486	50.99
25.12.2019	54767	56.29	11513	50.37
26.12.2019	54862	56.81	11581	50.57
27.12.2019	54697	59.94	11462	51.8
28.12.2019	54818	59.46	11549	51.61

29.12.2019	54822	58.64	11552	51.29
30.12.2019	54811	57.52	11544	50.85
31.12.2019	55059	67.24	11722	54.66