

HPF CEMS data for the period from October to December-2020

Name of the Stack	Date	Flue gas flow (Nm ³ /Hr)		SPM (mg/Nm ³)	
		KSPCB limit	Achieved	KSPCB limit	Achieved
Recovery boiler stack	06.10.2020	Max. 1,06,000	53224	Max. 150	67.3
	23.10.2020		55741		66.6
	03.11.2020		54329		64.5
	27.11.2020		55822		67.6
	04.12.2020		55877		67.2
	21.12.2020		55614		65.5
Lime kiln Stack	10.10.2020	Max. 18,000	12703	Max. 150	55.6
	17.10.2020		12013		53.0
	11.11.2020		11918		55.4
	23.11.2020		11570		55.1
	13.12.2020		11791		54.9
	28.12.2020		11514		54.7