

HPF CEMS data for the period from July-2021 to Sep-2021

Name of the Stack	Date	Flue gas flow (Nm ³ /Hr)		SPM (mg/Nm ³)	
		KSPCB limit	Achieved	KSPCB limit	Achieved
Recovery boiler stack	06.07.2021	Max. 1,06,000	52,135	Max. 150	60.1
	22.07.2021		54,322		61.2
	09.08.2021		52,111		60.2
	24.08.2021		52,321		60.9
	04.09.2021		52,864		61.2
	25.09.2021		52,594		60.1
Lime kiln Stack	12.07.2021	Max. 18,000	11,673	Max. 150	51.9
	30.07.2021		11,555		52.1
	16.08.2021		11,355		50.8
	31.08.2021		11,521		51.2
	15.09.2021		11,298		50.9
	29.09.2021		11,156		50.1